


工場内配置



測定項目	規制基準値	6/5(水)		6/12(水)		6/19(水)		6/26(水)	
測定時間(午前・午後)		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05(dB)	85.0	64.7	66.1	65.1	63.6	65.9	65.3	65.7	65.8
振動L10(dB)	75.0	41.6	45.3	40.2	40.4	40.2	39.4	40.9	39.7