


2024(令和6)年度2月

騒音・振動測定値報告



工場内配置



測定項目	規制基準値	2/5 (水)		2/12 (水)		2/19 (水)		2/26 (水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
測定時間(午前・午後)									
騒音L05(dB)	85.0	69.4	69.5	66.2	66.7	65.8	65.7	66.3	64.3
振動L10(dB)	75.0	43.7	40.3	42.9	43.7	45.7	49.8	44.0	43.5